



भारत सरकार
Government of India

FORM NO : NTH/ALP/F/5



राष्ट्रीय परीक्षण शाला (पूर्वी क्षेत्र)
National Test House (Eastern Region)

11/1 जजसे कोर्ट रोड, अलीपुर, कोलकाता - 700 027

11/1, Judges' Court Road, Alipore, Kolkata - 700 027

Number of Copies issued

Single

TEST CERTIFICATE

INTERIM/FINAL REPORT

परीक्षण प्रमाण पत्र सं
Test Certificate No

जारी होने की तिथि

Date of Issue

कोड नं

Code No

पृष्ठ

Page

पृष्ठों की संख्या

No of Pages

NTH(ER)/CH(H)/2022/0019

13/05/2022

1651742256191

1

2

जिसे जारी करना है

Issued To

पता

Address

RUDRA ENTERPRISE

81/19 -A Makarpura GIDC Near Vadsar Bridge Gujrat
aluminium,Vadodara,Gujrat-390010

ग्राहक का सन्दर्भ सं एवं दिनांक

Customer's Ref. No.

RE1/TEST/CN/22

Date: 02/05/2022

पंजिका सं एवं दिनांक

Register No & Date

0019/NTH(ER)/CH(H)/06/05/2022

परीक्षण सामग्री का विवरण

Description of Test Item

CANVAS FABRIC COATED WITH
FIRE RESISTANT (COATING/PAINT-ROYAL PAINT)

परीक्षण सामग्री का पहचान

Identification of Test Item

Sample received in an envelope describe as FIRE RESISTANT
COATING/PAINT ON CANVAS FABRIC Colour: BLUE/Any
Batch No REF/01/22
Mfg Date :25.04.2022 Mfg By Rudra Enterprise

नमूना का विशिष्टि (यदि हो)

Product Specification (If any)

Not Specified.

नमूना प्राप्ति की तिथि

Date of Receipt of the Test Item

05/05/2022

कार्य सम्पादन की तिथि

Date(s) of Performance of Tests

From: 06/05/2022

To: 11/05/2022

On the lines of BS 476 Part-7 1997

व्यावहृत प्रणाली का पहचान

Method(s) used for Test

Random

नमूना प्रक्रिया जहाँ प्रासंगिक हो

Sampling Procedure where relevant

Tested By

Sona Ram Baskey

SA(Chemical)

Checked By

Ajay Apparao Ukarande

Scientist- B (Chemical)

Approved By

Ajay Apparao Ukarande

Scientist- B (Chemical)



भारत सरकार
Government of India

FORM NO : NTH/ALP/F/5



राष्ट्रीय परीक्षण शाला (पूर्वी क्षेत्र)
National Test House (Eastern Region)

11/1 जजेस कोर्ट रोड, अलीपुर, कोलकाता - 700 027

सत्यमेव जयते
Number of Copies issued

Single

TEST CERTIFICATE

INTERIM/FINAL REPORT

परीक्षण प्रमाण पत्र सं
Test Certificate No

जारी होने की तिथि

Date of Issue

कोड नं

Code No

पृष्ठ

Page

पृष्ठों की संख्या

No of Pages

NTH(ER)/CH(H)/2022/0019

13/05/2022

1651742256191

2

2

Sl. No.

Test Name

Test Result

Limit

1

Surface Spread of
flame test BS 476
Part 7

a) Flame spread at 1.5 minutes = 175 mm
b) Final spread of flame at 10 minutes = 190 mm
c) The sample is burning continuously throughout the test and flame is not extinguished & forms ash.

For Class I : 165 mm (with tolerance 25 mm) for Class -2 250 mm (with tolerance 25 mm)

टिप्पणी

Note

: Note: These test results alone will not assess the fire hazard of the material or a product made from it under actual fire condition. Also these results alone can not be quoted in support of claims w.r.t the fire hazard. The results alone can be used for only R&D, Quality control and material application.

: Nil

कैफियत

Remarks

NOT LEGALLY USE

Tested By

Sona Ram Baskey

SA (Chemical)

Checked By

Ajay Apparao Ukarande

Scientist- B (Chemical)

Approved By

Ajay Apparao Ukarande

Scientist- B (Chemical)